



MUNICIPAL CORPORATION OF DELHI
OFFICE OF THE DEPUTY HEALTH OFFICER SOUTH ZONE
PUBLIC HEALTH DEPARTMENT
SRI AUROBINDO MARG NEW DELHI-110016
dhosouthzone@gmail.com



DHO/SZ/MCD/2023/D- 3352

DATE: 11/01/2024

SCHOOL HEALTH CERTIFICATE

It is certified that an inspection team headed by Sh. Kuldeep Rana (Public Health Inspector) from Public Health Department, South Zone, inspected the Sahoday Sr. Sec. School on 01.01.2024. The school is being run by Sahoday Sr. Sec. School Situated at C-1, Safdarjung Development Area, New Delhi – 110016.

It was found that The Sahoday Sr. Sec. School Running has safe drinking water facilities for the students and members of staff of the institution and is maintaining hygienic and sanitation condition in the school building and the campus.

The above certificate is valid for one year from date of issue, date of issue to renewal Fire NOC from Delhi Fire Services ending on 01.09.2024.


Dy. Health Officer
South Zone
Dr. Sanjay Sinha
Dy. Health Officer/SZ

Copy to:-

- Principal/Authorized Signatory
Sahoday Sr. Sec. School
C1, Safdarjung Development Area,
New Delhi – 110016
- Office Copy.

"STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance"



Delhi Jal Board

DELHI JAL BOARD
(GOVT. OF N.C.T. DELHI)
QUALITY CONTROL ZONAL LABORATORY (SOUTH)
WATER WORKS OKHLA DELHI-110025



Licence No- CRO/QM/L-8004290 IS/ISO 9001:2015



एक कदम स्वच्छता की ओर

Dated:01.12.2023

No. DJB/DTQC/ CWA (W&S)III / ACWA (south)/ Bact/P.S./2023-2024/080-081/29.11.2023

Bacteriological Analysis Report as per IS 10500:2012

To M/s Sahoday School

C- 1,Safdarjung Development Area

New Delhi -110016

Party Ref.No./Date: SSSS/DJB/SDW/06/2023-
24/26.10.2023

Deptt.Challan No. /date: 332/25.10.2023

Dt.of sample collection: 29.11.2023

No. of Sample: Two(02)

Collected by: Name- Smt. Pankajini Pati

Desig.- Lab Technician

SL.No.	Particulars	Clarity	Residual chlorine	Total coliform/ E.coli in 100 ml sample
1.	UGT Near Play Ground, Sahoday School	Clear	1.56	0
2.	Water Cooler Near Canteen, Ground floor	Clear	NIL	0

RESULT:- Collected water sample as mentioned above at Sr.No. 1, 2 were found bacteriologically satisfactory, hence the water/source is fit for drinking/recreational purpose subject to satisfactory attached Physical-Chemical Analysis report also.

01/12/23
Dr.D P Singh
ACWA (SOUTH ZONE)

01/12/23
BACTERIOLOGIST

01/12/23
ASST/BACT.